

THE DIVISION OF FIRE SAFETY

CERTIFICATE OF FITNESS(TQP) PROGRAM:

STATE CERTIFICATION	STATE CATEGORY	REQUIRMENTS FOR CERTIFICATION	CONTINUING EDUCATION REQUIREMENTS
Design, installation, inspection, maintenance and testing of fire alarm and detection systems and equipment	T1	A current Vermont Master Electrician, Journeyman Electrician and Type-S Journeyman Electrician in Commercial Fire Alarms	8 hours of related instruction
Design, installation, inspection, servicing or recharging of fixed fire extinguishing systems	T2	1) A current certificate from the National Institute for Certificate in Engineering Technologies (NICET) for fire suppression or 2) Training by the manufacturer of fire suppression systems acceptable to the Division of Fire Safety.	8 hours of related instruction
Installation, maintenance, repair and testing for fire sprinkler and standpipe systems , including private underground and aboveground fire mains and fire pumps	T3	1) Completion of an approved fire sprinkler apprentice program or 2) Proof of 4 years documented supervised installation, maintenance, repair, and testing experience as well as passing grade on the Sprinkler Fitter examination given in Barre, VT	15 hours of related instruction
Calculations and design for fire sprinkler and standpipe systems , including private underground and aboveground fire mains and fire pumps NOTE: A person with a this TQP shall also be permitted to install, maintain, repair and test fire sprinkler and standpipe systems	NICET	1) A current level III certificate, or higher, for automatic fire sprinkler systems from NICET 2) or a Current State of Vermont Fire Protection Engineer license	A current NICET certificate or a current Vermont Fire Protection Engineer license
Cleaning, maintenance and evaluation of chimneys	T4	A current certificate from the Chimney Safety Institute of America	A current certificate from the Chimney Safety Institue of America
Installation, maintenance, repair and testing for emergency generators	T6	Documented competency and experience through training by the manufacturer acceptable to the Division of Fire Safety	8 hours of related instruction

STATE CERTIFICATION	STATE CATEGORY	REQUIRMENTS FOR CERTIFICATION	CONTINUING EDUCATION REQUIREMENTS
LIMITED installation, maintenance, inspection and testing for domestic fire sprinkler systems with not more than 6 sprinklers for any isolated hazard area in accordance with 101:9.7.1.2 or an automatic fire sprinkler in accordance with NFPA 13D, Standard for Installation of Sprinkler Systems in One and Two Family Dwellings and Manufactured Homes, including multipurpose piping systems	T8	Documented competency and experience acceptable to the Division of Fire Safety to include a valid Master Plumber License and show proof of certified training from Uponor	8 hours of related instruction
LIMITED installation, repair and maintenance of oil burning equipment not including placing a new unit in service	OB	A Bronze certificate from National Oilheat Research Alliance(NORA)	8 hours including at least 2 hours regarding the prevention of CO leakage and the procedure for inspection
Installation, inspection and service of oil burning equipment	OS	A Silver certificate from NORA	8 hours including at least 2 hours regarding the prevention of CO leakage and the procedure for inspection

IMPORTANT INFORMATION

- All TQP certifications are for three (3) years.
- Continuing education must be completed within a licensee's 36-month certification period.
- Continuing education cannot be used for more than one renewal.
- Tax Certification required by 32 V.S.A. Section 3113 and Child Support Certification required by 15 V.S.A. Section 795 must be signed and included with this renewal.